# CURRENT YEAR FIRE ALARM INCIDENT LOG

Note: this does not include drills.

Note 2: Does not include individual room/suite smoke detector activations.

| Year | Date | Incident | Location | Cause | Injuries | Death | Property Value |
|---|---|---|---|---|---|---|---|
| **2017-18** | 9/11/17 | Sprinkler Activation | Penfield Hall Room 223 | Under review | 0 | 0 | Under review |
| | 10/23/17 | Local Smoke Detector Activation | Bellamy Hall Suite 314A | Student Had A Fog Machine | 0 | 0 | $0 |
| | 10/29/17 | Fire Alarm | Huntington Hall | Hair Styling Equipment Activated Smoke Detector | 0 | 0 | $0 |
| | 12/4/17 | Fire Alarm | Bellamy Hall | Burnt Macaroni & Cheese in suite gathering room microwave | 0 | 0 | $0 |
| | 12/5/17 | Fire Alarm | Butterfield Hall | Smoke Detector Activated in Hallway 209 | 0 | 0 | $0 |
| | 2/20/18 | Local Smoke Detector Activation | Bellamy Hall Suite 203C | Smoke Detector Activated due to Vaping | 0 | 0 | $0 |
| | 3/29/18 | CO Detector Activation | South Halls | Hot Water Heater Malfunction | 0 | 0 | Est. $6000 |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |