

CURRENT YEAR FIRE ALARM INCIDENT LOG

Note: this does not include drills.

Note 2: Does not include individual room/suite smoke detector activations.

Year	Date	Incident	Location	Cause	Injuries	Death	Property Value
2016-2017	8/25/16	Fire Alarm	Butterfield Hall	Odor in building. UFD confirmed exhaust from exterior generator entered building during extended power outage.	0	0	\$0
	8/29/16	Suite Smoke Detector	Bellamy Hall Suite 205	Visible Steam From Shower	0	0	\$0
	8/30/16	Suite Smoke Detector	Bellamy Hall Suite 113	Use of Electronic Cigarette (Vape)	0	0	\$0
	9/10/16	Fire Alarm	Huntington Hall	Pulled Alarm	0	0	\$0
	9/28/16	Fire Alarm	Daugherty Hall	Heat Detector – believed to have been intentionally tampered with.	0	0	\$110
	10/03/16	Fire Alarm	Daugherty Hall	Bathroom Smoke Detector Activation due to steam or marijuana smoke.	0	0	\$0
	10/04/16	Fire Alarm	Daugherty Hall	Same as above – 2 hours later again.	0	0	\$0
	10/13/16	Fire Alarm	Bellamy Hall Suite 114	Alarm set off by hair straightener.	0	0	\$0
	10/19/16	Fire Alarm	Bellamy Hall Suite 306	Alarm set off by hair straightener	0	0	\$0
	10/21/16	Fire Alarm	Penfield Hall	Steam from shower set off smoke detector	0	0	\$0
	11/10/16	Fire Alarm	Bellamy Hall Suite 311	Alarm set off by hair equipment	0	0	\$0
	11/4/16	Fire	Bellamy Hall Kitchen	Food on stove ignited. Extinguisher used.	0	0	\$0
	11/8/16	Fire Alarm	Bellamy Hall Suite 212B	Alarm set off by hair straightener.	0	0	\$0
	10/25/16	Fire Alarm	Bellamy Hall Suite 306	Alarm set off by hair equipment	0	0	\$0
	1/24/17	Fire Alarm	Bellamy Hall	Undeterminable. Smoke Detector activation.	0	0	\$0
	2/16/17	Fire Alarm	Bellamy Hall Suite 212	Hair Dryer	0	0	\$0
	2/19/17	Fire Alarm	Bellamy Hall Suite 306	Hair Dryer	0	0	\$0
	2/20/17	Fire Alarm	Bellamy Hall Suite 306	Hair Dryer	0	0	\$0
	4/2/17	Fire Alarm	Butterfield Hall 111 Bathroom	Smoking in the bathroom	0	0	\$0
	4/20/17	Fire Alarm	Daugherty Hall 310	Alarm set off by hair styling equipment	0	0	\$0
	4/23/17	Fire Alarm	Bellamy Hall Suite 215	Air-Freshener set off alarm	0	0	\$0
	4/28/17	Fire Alarm	Huntington Hall	Deodorizer set off alarm	0	0	\$0

5/5/17	Fire Alarm	Bellamy Hall Suite 306	Hair straightener	0	0	\$0
--------	------------	---------------------------	-------------------	---	---	-----