CURRENT YEAR FIRE ALARM INCIDENT LOG

Note: this does not include drills.

Note 2: Does not include individual room/suite smoke detector activations.

2018-19	Date	Incident	Location	Cause	Injuries	Death	Property Value
	9/30/18	CO Detector	Huntington Basement	Ventilation	0	0	\$0
	10/23/18	Fire Alarm	Butterfield Hall	Burnt Popcorn	0	0	\$0
	11/4/18	CO Detector	Daugherty Hall	Laundry Room Vent Backdraft	0	0	\$0
	11/4/18	CO Detector	Daugherty Hall	Backdraft	0	0	\$0
	11/5/18	Fire Alarm	Daugherty Hall	Steam from Shower activated Smoke Detector	0	0	\$0
	11/14/18	Fire Alarm	Huntington Hall	Vaping	0	0	\$0
	11/17/18	Fire Alarm	Huntington Hall	Pull Station activated by sports inside	0	0	\$0
	11/27/18	Fire Alarm	Huntington Hall	Unknown	0	0	\$0
	12/5/18	CO Detector	Bellamy Hall	Flooded bathroom above leaked into unit	0	0	\$0
	12/12/18	Fire Alarm	Butterfield Hall	Burnt Popcorn	0	0	\$0
	1/14/19	Fire Alarm	Bellamy Hall	Burnt food in microwave	0	0	\$0